



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/School/2024/SZ/ 922

Dated: 23/09/2024

FIRE SAFETY CERTIFICATE

Certified that the **Sanskriti School** located at Plot No. 34, 35, 36, Dr. S. Radhakrishnan Marg, Chanakyapuri, New Delhi-110021, comprised of Junior Block: G+02, Senior Block: G+3, Library Block: G+2, Dinning Block: G+2, Auditorium: B+G+2, Annexe Block: B+G+3, Admin Block: Lower GF, Ground & 1st Floor, Gymnasium Block= Ground floor only has already been issued Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/2021/SZ/841 dated 11/10/2021. The premise was re-inspected by the officer concerned of this department on 02/09/2024 in the presence of Mr. Dhruvender Singh (Estate Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in according with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class "Educational Building" (Group-B) as above with effect from 23/09/2024 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS Rules, 2010.

Issued on 23/09/2024 at New Delhi by

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Principal, Sanskriti School at Plot No. 34, 35, 36, Dr. S. Radhakrishnan Marg, Chanakyapuri, New Delhi-110021
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Conditions for the validity of Fire Safety Certificate:

1. **Basement shall be used strictly in accordance with the Building Bye Laws.**
2. All the means of escape / entry / exit shall be kept free from any obstruction.
3. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times as seen during inspection. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".